

C Systems Pvt Ltd	WLD MASTER	Doc. No:CSPL/wld8znew/230217
		Date: 23-FEB-2017
	Water Leak Detection System MODBUS Address Specification	Issue Rev.: 1.01
		Page 1 of 1

Modbus Address:

Description	Address	Function Code	R / W
ZONE STATUS FROM 1 TO 8	1001 – 1008 for Zone 1 - 8	0x03	R

Modbus Values:

Disabled	-	1
Healthy	-	2
Fault	-	3
Alarm	-	4
Isolated	-	5

Function Code:

0x03	-	Read holding register
R	-	Read only

Number of registers:

8

Modbus RTU Parameters:

ID or Address	- Configurable by user
Baud rate	- 9600 bps
Stop bit	- 1
Parity	- None
Data bits	- 8 bits