

C Systems Pvt Ltd	<b>WLD MASTER</b>	Doc. No:CSPL/wldmas/230217
		Date: 23-FEB-2017
	<b>Water Leak Detection System Master MODBUS Address Specification</b>	Issue Rev.: 1.01
		Page 1 of 1

**Modbus Address:**

Description	Address	Function Code	R / W
ZONE STATUS OF MODULE FROM 1 TO 8	1001 – 1008 for Module 1 - 8	0x03	R

**Modbus Values:**

Disabled	-	1
Healthy	-	2
Fault	-	3
Alarm	-	4
Isolated	-	5

**Function Code:**

0x03	-	Read holding register
R	-	Read only

**Number of registers:**

8